

## **BUILDING & SAFETY DIVISION POLICIES & PROCEDURES**

### **Policy No. PP-11 Electric Permits for Fireworks Booths**

A miscellaneous electrical permit (PME) is required when electrical power of any type is supplied to the booth.

Electrical permits are not required if there is no electrical wiring in the booth supplied by any source of power such as extension cords, generators, or temporary power poles.

The following requirements will apply if electrical power is to be supplied to booth:

- All wiring shall be GFCI protected.
- All wiring shall be in an approved raceway or type MC cable. No exposed wiring, or open splices are allowed in any type of wiring.
- Any extension cords shall be labeled *S.O Heavy Use* and must be protected in any path of travel.
- Generators shall be at least 50' from the stand, or in a safe location as determined by the Building Inspector and the Fire Inspector.
- All fixtures shall be of the enclosed type.
- No extension cords are permitted inside the stand.

These permits will be a minimum value permit, and are intended to provide a safety inspection of the electrical service.

---

Cyrus Abhar  
Chief Building Official, City of Rancho Cordova