

CHRISTMAS TREE SALES LOT INFORMATION

Business License # _____ Permit # _____

Business Owner _____ Address _____

Doing Business As _____

Lot Address _____ Nearest Cross Street _____

Local Phone Number _____ Zone _____

Will there be any yard lighting or Christmas tree lights on this lot? Yes No

Power will be supplied by: Existing circuit Temp. Power Pole Portable Generator

The following electrical standards are mandatory in City of Rancho Cordova Code under the provisions of the City of Rancho Cordova Electrical Code:

1. No electrical installation may be started unless the installer has secured an electric permit.
2. Strings of lighting above Christmas trees or the lot must clear the ground by a minimum of 10 feet above pedestrians and 18 feet above commercial areas, parking lots, agricultural, or other areas subject to truck traffic.
3. Where using cords, only Type S (heavy duty) cords may be used. No cords will be allowed to be routed across walkways. All connection boxes or plugs will be located at least 6 inches above ground. No electrical cords can be woven into metal fencing.
4. All electrical shall comply with the provisions of the 2007 CEC article 590 Temporary Installations.
5. When all electrical work has been completed, call 851-8766 for the required inspection.

I, the undersigned licensee or authorized agent, understand that, if I violate any of these provisions, the Business License for the Christmas Tree sales at this location may be subject to revocation; and my right to sell Christmas Trees at this location will terminate with the revocation of the Business License.

Signature of Licensee or Authorized Agent _____ Date _____