

# Sign Permits

## To Schedule an Inspection

Call: (916) 851-8766 up to 6:00 AM of the morning of the day you want the inspection

## Required Inspections:

**Footing Inspection (101) is required for Monument and Pole  
Signs only**

**AND**

**Final Structural (199) is required for ALL signs**

## Common Inspection Problems:

1. City sign label (R-number) not installed on sign (City Code).
2. Electric wall and monument signs require disconnect within sight of the sign. (If disconnect is internal, a label stating "Switch Inside" should be placed on the exterior of the sign or raceway.) CEC 600-2.
3. Improper grounding. (Flex is not a proper ground if the total accumulated length of flex exceeds 6 feet.) CEC 600-5 and 250-91(b) Exception No. 1.
4. GTO cable not properly supported within raceways. (Standoff supports will give the required clearances.) CEC 600.23.
5. Glass insulating sleeves not used when GTO cable passes through raceway barriers. CEC 600-31d.
6. Use bushings for 120-volt line wiring when penetrating raceway barriers. CEC 600-24.
7. UL label on all components of the sign. CEC 600-4.
8. Manufacturer's label stating input volts and amps on sign. CEC 600-7a.